



PLANNING & COMMUNITY DEVELOPMENT



P.O. Box 905
1048 Carriage Oaks Drive
Carthage, NC 28327
Planning: 910.947.5010
Central Permitting: 910.947.2221
Fax: 910.947.1303
www.moorecountync.gov

TO: All Contractors

FROM: Carlis P. Sweat

DATE: August 26, 2016

SUBJECT: Pre-Bid Walk-Thru Questions and Answers

The following question(s) (below) were asked during the mandatory Pre-Bid Walk-Thru held on August 25, 2016. Answers are organized by the way the home was labeled on the work write-up and in the order they were visited.

*****Receipt of this Addendum must be acknowledged by its inclusion with the Proposal and noted as an inclusion on the sealed envelope.*****

The following clarifications are hereby made to the original bid:

URP15: Home #18

Q: How do we properly wire the generator into the sub panel being installed?

A: All work performed for Moore County Community Development Rehab projects shall conform to N.C. Building and Electrical Codes as stated on page #1 under Requirements For All Work Write-Ups.

- The generator shall be wired according to Article 702 of the 2014 National Electrical Code Optional Standby Systems and will be inspected & approved as such.

SFR14: Home #6

Q: No questions.

URP15: Home #19

Q: No questions.

URP15: Home #18

Q: No questions.

*****Receipt of this Addendum must be acknowledged by its inclusion with the Proposal and noted as an inclusion on the sealed envelope.*****